



Presented to:
HPSC Contractor Forum

IMPROVING CUSTOMER SATISFACTION: LEASONS LEARNED FROM A RESIDENTIAL AIR TO AIR HEAT PUMP CASE STUDY

Todd Backus, P.Eng.

Rob Pope

April 29th, 2026



ecolighten
ENERGY SOLUTIONS

AGENDA

1. Discovery
2. Case Study
3. CSA F280 Calculation
4. Homeowner Complaint
5. Measured Airflows
6. Deficiencies
7. Fixing the Problem
8. Q & A



DISCOVERY

Checklist for Retrofit Pre-Changeout Procedure:

- ✓ Suitability of existing distribution system (e.g. ductwork capacity and static pressure check)
- ✓ Electrical panel/service capacity
- ✓ Envelope performance / airtightness (Energuide evaluation)
- ✓ CSA F280-12 Load Calculations



DISCOVERY

A 'Discovery Session' is the foundation to successful project planning, to ensure project goals and client needs are established upfront.

ASK QUESTIONS

What is your experience with the existing HVAC equipment and distribution system?

What are your motivations for upgrading to a heat pump system?

Are you planning any further energy upgrades to your home?

DISCOVERY

Discuss Occupants' Needs and Expectations:

- **Current conditions** - how the HVAC system has been working?
- **Aesthetics** – any issues/concerns with wall mounted units, external piping or outdoor unit placement?
- **Primary motivation factor** – cost savings, rebates, GHG reduction, emergency replacement?
- **Budget** – upfront and operational cost considerations?
- **Comfort & Health** – what is comfortable, what temperatures, are there health issues, allergies, other sensitivities including noise?

DISCOVERY

CAN/CSA F280-12: Canadian Standards Association (CSA) standard on how to properly size residential space heating and cooling equipment that is nationally recognized and referenced in the BC Building Code (Section 9.33.5)

Making sure this standard is used can:

- ✓ Ensure comfort
- ✓ Reduce installed HVAC system costs
- ✓ Ensure you comply with code
- ✓ **Reduce your liability risks**



F280-12

Determining the required capacity of residential space heating and cooling appliances



SITE INFO

- **Location: Victoria, BC**
 - Built in 2023
- **2,500 ft² Floor Area**
 - Separate basement suite
- **Centrally ducted system**
 - Furnace
 - Air to Air Heat Pump
- **HRV for ventilation**
 - Outdoor air supplied to return air duct
 - Independent exhaust



CSA F280 QUESTION

What are the heat loss & heat gain BTUH results?

- Outdoor design temperatures:
 - Heating: 22°C, 71.6°F
 - Cooling: 24°C, 75.2°F
- Area: 2,048 ft²
- Occupancy: 3-bedroom, 4 people
- Assemblies:
 - Walls: R-20
 - Ceilings: R-40
 - Windows: USI: 1.96 & SHGC: 0.47



F280-12

**Determining the required capacity of
residential space heating and cooling
appliances**





CALCULATION RESULTS

HEAT LOSS & HEAT GAIN SUMMARY, (BTUH)			imperial		
ROOM NAME	FLOOR LEVEL	FL AREA (ft ²)	HEAT LOSS	HEAT GAIN	
			TOTAL	SENS.	TOTAL (sensible + latent)
(#1)Basement	1	206	2346	3	4
(#2)Kitchen	2	230	1651	2380	3094
(#3)Dining & Great Room	2	300	2367	4299	5588
(#4)Pantry	2	69	210	11	15
(#5)Mudroom & Hall	2	90	584	9	12
(#6)Foyer	2	97	864	437	568
(#7)Half Bath	2	32	281	6	8
(#8)Ensuite	3	117	1011	997	1296
(#9)WIC	3	78	272	63	81
(#10)Main Bath	3	52	182	42	54
(#11)Laundry	3	32	212	29	38
(#12)Bedroom 2	3	136	1750	1657	2154
(#13)Bedroom 3	3	140	1030	667	867
(#14)Bonus, Hall & Stairs	3	261	836	901	1172
(#15)Primary Bedroom	3	208	1674	1353	1759
		AREA	HEAT LOSS	GAIN (sens.)	GAIN (total)
OVERALL BUILDING		2048	15268	12853	16708


ZONE CONTROL

- Heating and cooling loads change throughout the year
- Zone control of this system can only be achieved by opening and closing grilles
 - Duct system too small to close grilles?
- Single thermostat on main floor



CUSTOMER COMPLAINT

- Poor thermal comfort, especially on the top floor
 - System is worse in cooling mode
- Inconsistent temperature throughout the home




COMPLAINT TIMELINE

- Customer complained to builder
- HVAC contractor has been to site multiple times
 - Cannot resolve the issues to the customer's satisfaction
- Customer has escalated the complaint to the insurance company
- Customer hired an independent contractor to analyze the system

What do you think the results of the report are?

FOUNDATION PLAN

No return or supply air to basement



- NOTES:**
- NO RETURN AIR IN BASEMENT
 - NO OUTDOOR AIR SUPPLIED TO BASEMENT
 - NO HEATING SUPPLIED TO BASEMENT OF MAIN SUITE
 - NO DUCT TAKE-OFF FITTINGS IN MECHANICAL ROOM
 - NO DUCT TRUNK REDUCTION IN MECHANICAL ROOM
 - NO P-TRAP ON HRV
- SECONDARY SUITE:**
- SECONDARY SUITE VENTILATED BY PASSIVE GRILLES
 - SECONDARY SUITE HEATED BY ELECTRIC BASEBOARDS


FOUNDATION PLAN
769 Sq. Ft.

NOTE:
- FULL HEAT PUMP INSTALLATION

MAINFLOOR PLAN

Supply Air:
487 cfm

Return Air:
738 cfm




MAIN FLOOR PLAN
849 Sq. Ft.

TOP FLOOR PLAN

**Supply Air:
329 cfm**

**Return Air:
0 cfm**

**Exhaust Air:
78 cfm**



- NOTES:
- MEASUREMENTS TAKEN ON COOLING MODE & NORMAL OPERATION OF HRV
 - SUPPLY AIRFLOW FOR TOP FLOOR: 329 CFM
 - EXHAUST AIRFLOW FOR TOP FLOOR: 78 CFM
 - NO RETURN AIR FROM TOP FLOOR

SECOND FLOOR PLAN
1011 Sq.Ft.

SUPPLY AIRFLOW RESULTS

		HEAT LOSS (DESIGN)		HEAT GAIN (DESIGN)		INSTALLED (MEASURED ON COOLING)	DIFFERENCE FROM MEASURED TO HEAT LOSS	DIFFERENCE FROM MEASURED TO HEAT GAIN
ROOM #	ROOM NAME	LOSS [BTUH]	AIRFLOW [CFM]	TOTAL [BTUH]	AIRFLOW [BTUH]	AIRFLOW [CFM]	AIRFLOW [CFM]	AIRFLOW [CFM]
1	Basement	2,346	125	4	0	0	-125	0
2	Kitchen	1,651	88	3,094	151	30	-58	-121
3	Dining & Great Room	2,367	127	5,588	273	249	122	-24
4	Pantry	210	11	15	1	0	-11	-1
5	→ Mudroom & Hall	584	31	12	1	96	65	95
6	Foyer	864	46	568	28	50	4	22
7	→ Half Bath	281	15	8	0	62	47	62
8	Ensuite	1,011	54	1,296	63	0	-54	-63
9	WIC	272	15	81	4	0	-15	-4
10	→ Main Bath	182	10	54	3	48	38	45
11	→ Laundry	212	11	38	2	53	42	51
12	Bedroom 2	1,750	94	2,154	105	70	-24	-35
13	Bedroom 3	1,030	55	867	42	45	-10	3
14	Bonus, Hall, & Stairs	836	45	1,172	57	54	9	-3
15	Primary Bedroom	1,674	89	1,759	86	59	-30	-27
TOTAL		15,270	816	16,710	816	816	-	-

EXHAUST & RETURN AIR

Question:

In a single-family dwelling unit that is equipped with a heat recovery ventilator (HRV) and a forced air furnace, can an exhaust grille satisfy the requirement for a return air grille on the upper most floor level?





Figure 9.32.3.4.(3)
Forced-Air Heating System with Heat Recovery Ventilator Supply Air Distribution



EXHAUST & RETURN AIR

Interpretation:

NO!

Return air must be present on all floors in a centrally ducted system, per BCBC **9.32.3.4. (3)**

- Exhaust & return air serve different functions
- File No: 24-0035, Feb 18, 2025

BC BUILDING CODE INTERPRETATION COMMITTEE
A joint committee with members representing
AIBC, EGBC, BOABC

File No: 24-0035 **INTERPRETATION** **Page 1 of 2**

Interpretation Date:	February 18, 2025 (REVISED)
Building Code Edition:	BC Building Code 2024
Subject:	Exhaust Air Inlet as a Return Air Inlet in Dwelling Unit
Keywords:	Heat Recovery Ventilator (HRV), Forced-air Heating System, Exhaust Air, Return Air
Building Code Reference(s):	9.32.3.4.(3); Table 9.32.3.5.; Note A-9.32.3.; Figure 9.32.3.4.(3); 9.33.4.1.; 9.33.6.12.(2),(3); Note A-9.33.6.13.

Question:
In a single-family dwelling unit that is equipped with a heat recovery ventilator (HRV) and a forced air furnace, can an inlet to an exhaust air duct satisfy the requirement for a return air inlet on the upper most floor level?

Interpretation:
No.

Exhaust duct is defined as a duct through which air is conveyed from a room or space to the outdoors. Return duct means a duct for conveying air from a space being heated, ventilated or air-conditioned back to the heating, ventilating or air-conditioning appliance. They serve different purposes.

Subsection 9.32.3. applies to heating-season mechanical ventilation. Sentence 9.32.3.4.(3) regulates ventilation system with a combination of a ducted forced-air heating system and an HRV. It requires that "the HRV shall draw exhaust air, through dedicated ducting from one or more indoor inlets, at least one of which is located at least 2 m above the floor of the uppermost floor level and at the capacity rating of the HRV, which shall be no less than the air-flow rate specified in Table 9.32.3.5." The exhaust air is ducted directly to the HRV and then to the exterior without mixing with the forced-air heating system.

Patrick Shek

Patrick Shek, P.Eng., CP, FEC, Committee Chair

The views expressed are the consensus of the joint committee with members representing AIBC, EGBC and BOABC, which form the BC Building Code Interpretation Committee. The Building and Safety Standards Branch, Province of BC and the City of Vancouver participate in the committee's proceedings with respect to interpretations of the BC Building Code. The purpose of the committee is to encourage uniform province wide interpretation of the BC Building Code. These views should not be considered as the official interpretation of legislated requirements based on the BC Building Code, as final responsibility for an interpretation rests with the local Authority Having Jurisdiction. The views of the joint committee should not be construed as legal advice.

2025-02-27

COMMITTEE

Page 2 of 2

ing systems.
each floor level in a
e made for the return
s or installing return
The return-air is

icates an exhaust
e lower floor.

rements are
ethod for the

duced to the return
2.3. also provides

ddressed in this
quipment, shall be

h form the BC Building
ate in the committee's
uniform province wide
rements based on the
of the joint committee

EXHAUST & RETURN AIR

Airflows can be balanced using exhaust rather than return air in specific circumstances...

However; this is not appropriate for residential (Part 9) applications because it creates imbalanced systems and inconsistent temperatures through the building

This has been attempted many times and it always fails to produce a system that functions properly

CODE DEFICIENCY


- Return air not provided to the top floor
 - Only a single return air grille was installed, located on the main floor
 - Most of the basement belongs to the suite, which electric baseboard heat

BCBC: 9.33.6.12. Return-Air Inlets

- 2) Except for unfinished areas and floor levels which are less than 900 mm above or below an adjacent floor level which is provided with a return-air inlet, at least one return-air inlet shall be provided in each floor level in a dwelling unit.


ESP MEASUREMENTS

- External static pressures taken on site
 - Cooling: highest speed
- ESP from duct: 0.3"wc
 - High for a small system
- Don't forget the filter!



ELBOW SELECTION

- Elbows of return air drop have square throats
- Filter is only 1" in depth and is located directly beside the fan inlet





PLENUM TAKE-OFFS

- No plenum take-offs
- Return air duct tapped into trunk without a beveled fitting




BRANCH TAKE-OFFS

- No take-offs on trunks or branches
 - Dove-tailed pipes into trunks
- Elbow gores not sealed





BEST PRACTICE

- Supply air branches connected off the end caps



BEST PRACTICE

- No reducing cross sections on mechanical room ducts



BEST PRACTICE

- P-trap on HRV not installed
 - Easily fixed code deficiency
- HRV is set to a single speed
 - No controller installer
- Exhaust location is poor
 - Exhaust from bathrooms



REMEDIATION

- Add return air to the top floor
 - Requires a chase in the mudroom
 - Looks possible on site, requires a lot of finishing work
 - Quote received for \$7,000


- Who pays for the work?



IMPROVEMENTS

Improving system performance

- Seal visible ductwork
- Replace return air elbows with proper fittings
 - Turning vanes, or
 - Radius elbows
- Increase filter to 4" wide & relocate filter to return air drop





QUESTIONS & COMMENTS?



Todd Backus, P.Eng.

Chief Operating Officer

cell: 604.838.7511

email: tbackus@teca.ca



Rob Pope

Senior Consultant/Co-founder

phone: 604.971.2088

email: rob@ecolighten.com